

Corrigendum in Tender No. HWT110518495

In Scope of Work

Additional Note: Presently GSDC is monitoring existing PAC through existing Honeywell BMS, hence offered PAC should also be integrated with existing Honeywell BMS.

In Form no. T2 (TECHNICAL MINIMUM SPECIFICATIONS)

Sr. No	Item	Matched/ Not Matched	Deviation/ Remarks (If any)
Precision AC (30 TR Capacity)			
---	-----		
17	The unit shall incorporate the following protections: a. Single phasing preventers b. Reverse phasing c. Phase imbalancing d. Phase failure' e. Overload tripping (MCB) of all components		

Form no. F1 – Revised FINANCIAL BID FORMAT

Sr. No	ITEM	Qty. (In Nos.)	Unit Prices with Warranty (In Rs. Without tax)	Total Price (In Rs. Without tax)	Rate of GST (%)
A	B	C	D	E=C*D	F
1	Precision AC	2			
2	Installation cost of Precision AC which includes copper piping, thermal insulation of piping & other necessary items/ services etc. required for installation	2			
Grand Total					

Note:

- L1 will be the lowest sum total of rates of all line items without tax with warranty.

All other Scope of work & technical specifications are as per bid document