

**Date: 06/02/2017**

# **Corrigendum**

**in**

**Request for proposal (RFP) for Selection of Agency for Supply, Installation, Commissioning and Operations & Management of Wi-Fi Network at Villages, across Gujarat.**

**(GIL/DST/Village-WiFi/2016 dated: 29/12/2016)**

**(Revised bid Document dated: 23/01/2017)**

## **SECTION-V: Technical Specification**

**Please read Revised Technical Specification for UPS as follows:**

### **5.11 UPS**

<b>S/N</b>	<b>Parameter</b>	<b>Minimum Specifications</b>
1	Capacity	500 VA or more Line Interactive
2	Technology	Automatic Voltage Regulation
3	Input Frequency Range	50 Hz +/- 5%
4	Output Frequency Range	50 Hz +/- 5%
5	Output Voltage	220VAC - 230VAC
6	Voltage Regulation	+/-5% (or better)
7	Output Waveform	Modified sine Wave
8	Output Power Factor	0.6 or more
9	Protection	Fuse Protection
10	Battery Backup	Minimum backup of 15 Minutes on full load
11	Battery Type	Lead Acid, Sealed Maintenance Free (SMF)
12	General Operating Temperature	0 to 45 Degree Celsius
13	Alarms & Indications	All necessary alarms & indications essential for performance monitoring of UPS like mains fail, low battery
14	Bypass	Automatic, Manual Bypass Switch

**NOTE: All other tender terms & conditions and technical specifications remain unchanged.**