

## Corrigendum in Tender No. HWT200217414

### SECTION -5 ( UPS)

Sr. No.	Item		Matched/ Not Matched	Deviation/ Remarks (If any)
600 VA Line Interactive UPS (with 15 minutes Battery backup)				
22	600 VA Line Interactive UPS with 15 minutes Battery Back Up			
	General	Single Phase Input & Single Phase Output		
	-----	-----		
	AC Mode	AVR Output voltage in AC mode; 180-230 V +/- 10%; 50 Hz +/- 3 Hz		
	-----	-----		
	Minimum Battery AH	600 VA UPS – 84 VAH – 15 minutes Battery Back Up		

**All other technical specifications are as per revised bid document.**