

Response to pre-bid queries

Bid for Supply, Install, Commissioning and Maintenance of MCCB Panels with Enclosures for the use at Gujarat State Data Centre on behalf of Department of Science and Technology, Gandhinagar. (Tender No. HWT080319542)

Sr. No.	Query / Clarification / Suggestions from the Vendors	Responses of GIL
1	MCCB Rating, Type (Adjustable Thermal Magnetic or Microprocessor based), 3 Pole or 4 Pole and Make of MCCB	Thermal Magnetic MCCB Four Pole
2	MCCB required with or without door operating handle	With operating and locking handle.
3	Copper Flexible wire size (laying from Main Panel Busbar to MCCB Panel) for Phase, Neutral & Earthing	Four Core 35 sq. mm Copper base flexible (RR cable) length 30 Mtrs approx. with copper lugs
4	Number of MCCB Panels	03 quantity (already mentioned in RFP)
5	Modification work in existing Main Panel's vacant feeder. (1no MCCB to be fixed in vacant feeder of Main Panel)	Not required in empty enclosure, only mounting and connectivity with Bus Bar.
6	Type of Panel (Wall mounted or Floor mounted type) and Size of Panel	Wall Mounted and Size of panel (Approx. 1X1.5 ft.)
7	Material of Panel (CRCA/HR/GI) and its thickness	Similar to existing panel (CRCA)
8	Paint shade of Panel (Siemens Grey or Light Grey)	Similar to existing panel light grey.
9	Confirm that how many enclosure are require for this tender	Two