

Corrigendum-I

Request for Proposal (RFP) for Selection of Agencies for Design, Supply, Installation, Testing, Commissioning and Transfer of the Telecom Shelter Across the State of Gujarat for BharatNet Phase III Project On Behalf of Gujarat Fibre Grid Network Limited(GFGNL), Department of Science & Technology, Government of Gujarat

Issued by:

Gujarat Fibre Grid Network Limited

Reference No: GFGNL/GFG/e-file/263/2025/0041/Shelter infrastructure for BharatNet Phase-III (ABP)

Date: 23rd Jun 2025



Issued By:

Gujarat Fibre Grid Network Limited (GFGNL)

A Government of Gujarat Company

Block No: 6, 5th Floor, Udyog Bhavan, Sector-11, Gandhinagar 382010

Fact Sheet:

9.	Last date for submission of Bid/proposal	12/06/2025 23/06/2025 04/07/2025 at 06:10 pm
12.	Bid Security/ Earnest Money Deposit (EMD) Amount Payable	<p>Rs 1,07,65,000/- (Rs. One Crore Seven Lakh Sixty Five Thousands Only) Rs 60,000,00 /- (Rupees Sixty Lakhs Only) per package unconditional Bank Guarantee or Insurance Surety Bond in favor of "Gujarat Fibre Grid Network Limited" drawn payable at Ahmedabad/Gandhinagar</p> <p>Details of the Bank: Name of the Beneficiary: Gujarat Fibre Grid Network Limited Bank Name: HDFC Bank Ltd. Bank Account Number: 50200061 458239 IFSC code: HDFC0000190 MICR Code: 520011025 Branch Code: 000190 Branch Name: Sector 16, Gandhinagar Branch</p> <p>Note:</p> <ul style="list-style-type: none"> As per the GoG guideline, EMD should be in the form of BG as per the GoG GR No. FD/MSM/e-file/4/2023/4020/D.M.O. dated 11-03-2024 or latest regarding the Acceptance of Bank Guarantee as SD and EMD. DD/Pay orders are not accepted as EMD.

Annexure-I : Pre-Bid query Response/Clarification

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
1	SECTION-3 <u>QUALIFICATION CRITERIA</u>	3.1 Eligibility Criteria	23	<p>Company Turn-Over: The bidder should have average annual turnover of at least *11 Cr for single package *20 Cr for two packages</p>	<p>(1) Kindly consider average annual turnover as 7 Cr or 30% of project cost of Capex to bid for both the package. Alternatively, 50% exemption can be given to MSME on eligibility criteria.</p> <p>(2) Turnover criteria and other criteria has to be same for bidding in both the packages as bidder will be allotted only one package work finally. Please consider this and request to revise the clause accordingly.</p>	<p>For inclusive partnership, The following MSE related relaxation are allowed under the Official Memorandum(20th September 2016 & 27th January 2022).</p> <p>i)Turnover 50% relaxation ii)Experience 50 % relaxation</p>

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
2	SECTION-3 <u>QUALIFICATION CRITERIA</u>	3.1 Eligibility Criteria	24	Experience required One similar completed work Project *for One Package is Rs 16 Cr or 112 shelter *for both the package is Rs 26 Cr or 180 Shelters	Request to revise "one similar work experience" to 70 no's shelters from 112 no's shelters (which is approximately 50% of the total quantity of one package) and the same criterion for bidding in both the packages as the bidder will be allotted only one package work. As we are having very good financial capability and enough work experience to execute this new tender project efficiently. Please consider this and request to revise the tender clause accordingly.	PI see preceding response above in Query-01
3	SECTION-9 <u>GENERAL CLAUSES</u>	9.5 Bid Security/ Earnest Money Deposit (EMD)	89	i. Bidders shall submit, along with their Bids, EMD of Rs 1,07,65,000,-(Rs. One Crore Seven Lakh Sixty-Five Thousands Only) per package	1) Request to reduce EMD to 1% of the total project cost as per the government norms. 2) Only One EMD should be taken for bidding in both the package as only one package work will be given to one bidder. Please consider this and request to revise the tender EMD clause accordingly.	PI see revision, See the revised clause in Annexure-B
4	Section- 3	3.1 Eligibility Criteria (Legal Entity)	23	The bidders should be registered under the companies Act 1956/2013 in India or a limited liability Partnership Firm Under Limited Liability Partnership Firm Act 2008 at the time of the bidding submission date.	Humble Request that, Other than LLP (Limited partnership liability) firms, Partnership firms (Under Indian partnership act -1932) may also be included as a legal Entity to bid for this tender. In the previous bid for Telecom Shelters for BharatNet Phase II Project the same was incorporated (Screen Cap attached). (Partnership firms registered under the Indian partnership act 1932, prior to the enactment of the LLP act 2008, are serving as reliable business entities. Their proven operational efficiency & legal recognition and historical contribution justifies inclusion in tender eligibility, ensuring fair competition and wider participation from established, credible enterprises)	For the wider Participation, PI see revised clause in annexure C

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
5	Section-3	3.1 Eligibility criteria (Company Turover)	23	The bidder should have average annual turover as below from the buisness of telecom industry grade standardized shelter of at least 11 Cr for Single Package, 20 Cr for Two Package	Humble request to consider average annual turnover as *7.5 Cr for the last three financial year or *30% of the project cost of Capex or *20 Cr cumulative turnover of last three financial year. In the previous bid for Telecom Shelters for BharatNet Phase II Project the required turnover was 12 cr cumulative (Screen cap attached). Since your good office shall be allotting maximum of one package order to any successful bidder, the turnover and other eligibilty criteria may be the same for bidding for one package or both the package.	Duplicate Query, PI see preceding response above in Query-01
6	Fact sheet	Bid Security/Ear nest Money Deposit (EMD) Amount Payable	13	Rs 1,07,65,000/- (Rs One Croren Seven Lakh Sixty-Five Thousand Only) per Package.	Humble request for accepting one EMD for bidding in both the package as any successful bidder will be allotted maximum 01 package work order only. Also request to reduce the EMD Amount.	Duplicate Query, PI see preceding response above in query-03
7	Section-3	3.1 Eligibility Criteria (Experience)	24	One similer completed work project not less than (one package) Rs 16 Cr or 112 shelters, (Both the packageg) Rs 26 Cr or 180 shelters.	Humble Request to consider "one similar completed work project not less than 75 no's shelters" so as to ensure wider participation and fair competition. GOI has relaxed norms for MSME (vide policy circular no 1(2)(1) 2016-MA dated 10th March 2016) on prior experience and turnover criteria. In view of the above the experience and turnover criteria may kindly be relaxed upto 50% or more for MSME's.	Duplicate Query, PI see preceding response above- in query-01

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
8	Section- 9	General Clauses 9.17-Representations and Warranties (Point No. 14)	102	<p>14. For the newly created Shelter with all inventories and upgraded inventories. It is the bidder's responsibility to provide the AMC of newly created shelter with all inventories and upgraded existing shelter's inventories till the end of new contract duration (i.e. 10 years) from the successfully completion of FAT date under this RFP scope.</p> <p>The comprehensive onsite replacement warranty at fixed rate 3% of first 5 years and later 4% from the 6th to 10th year will be paid to new PIA separately as a part of AMC payment.</p>	<p>We Humbly submit the following request for your kind consideration regarding the comprehensive on-site replacement warranty payment criteria</p> <p>Given that the new shelters are being deployed with upgraded specifications, including the integration of multiple sophisticated equipment and accessories—many of which are also retrofitted into existing shelters—it may not be possible to do the AMC at given fixed percentage rate.</p> <p>Therefore, we humbly request that the Comprehensive Onsite Replacement Warranty rate (in percentage) be introduced as a separate line item in the financial bid table, allowing bidders to quote this component distinctly.</p> <p>This measure will not only ensure transparency and fairness in pricing but also help in avoiding an inflated capex quotation, which may otherwise result in undue financial burden to GFGNL and the Government of Gujarat.</p> <p>To maintain cost control , a maximum cap of 5% to 7% on this line item can be imposed.</p>	<p>It is a mandatory provision for the bidders related to AMC and O&M in compliances with ABP (Amended BharatNet Program) framework. The bidder may charge any perceived shortfall or any gap with fixed AMC/O&M defined in the RFP in CAPEX portion. This is for the ease of submission and extending level playing field for the all bidder.</p>

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
9	Section-7	Section 7.1 Payment criteria for new shelter	77	<p>50% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order.</p> <p>20% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order.</p> <p>30% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order.</p>	<p>We respectfully submit the following for your kind consideration with regard to the payment criteria outlined in Section 7.1 of the current bid document .</p> <p>In the interest of financial viability and smoother cash flow management during project execution, we humbly request that the following payment terms as provided in the previous bid be retained (Copy of Screen cap attached).</p> <p>70% of Capex value of the total work value for one porta cabin with infrastructure, payable at T4 + 90 calendar days, upon completion of SITC</p> <p>30% of Capex value of the total work value for one porta cabin with infrastructure, payable at T5 + 90 calendar days, after a cooling period of 3 months post-installation.</p> <p>We believe that this structure will support timely execution, reduce financial stress on the executing agency, and continue to safeguard the interests of GFGNL and the Government of Gujarat.</p>	Pl see revision

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
10	SECTION-4 SCOPE OF WORK	SCOPE OF WORK	50	k) Selected Bidder will have to do the shifting of shelter Infrastructure site (including all the items supplied & installed under the SoW of this RFP) from one location to other within (50 Km of radius range) if need arises in future for same & instructed by GFGNL. Shifting scope may vary up to 10% of total scope awarded without any additional cost to GFGNL. Beyond the 10% of the shifting scope, per site beyond the limit define above, GFGNL will pay Rs 50,000/- per site to selected bidder.	Request you for the inclusion of a separate line item for the shelter shifting scope of work within the Price Schedule. Currently, we note that there is no specific line item available to include the rates associated with shelter shifting activities. Including this scope of work separately will allow bidders to provide clear and distinct pricing for this particular activity.	Pl see revision in Annexure-B for revised clause.
11	Section-7 PAYMENT CRITERIA	7.1 Payment criteria for New Shelter	77	(1) 50% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order (2) 20% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order (3) 30% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order	We request that please consider the payment criteria outlined in the previous bid of Phase-II shelter work. Specifically, the criteria were as follows: * 70% of the Capex value of the Total work value for one porta cabin with infrastructure, as specified in the execution order, would be payable after successful SITC of shelter work with FAT and acceptance report from GFGNL. * The remaining 30% of the Capex value of the Total work value for one porta cabin with infrastructure, would be payable after 3 months of successful SITC of shelter site with all equipments along with clearance of punch point along with final acceptance report from GFGNL. We believe that adhering to these previously established payment terms would be beneficial for this current bid as well.	Duplicate Query, Pl see preceding response above in query -09

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
12	SECTION-9 GENERAL CLAUSES	9.17 Representati ons And Warranties	112	14. For the newly created Shelter with all inventories and upgraded inventories, It is the bidder's responsibility to provide the AMC of newly created shelter with all inventories and upgraded existing shelter's inventories till the end of new contract duration(i.e., 10 years)from the successfully completion of FAT date under this RFP scope. The comprehensive onsite replacement warranty at fixed rate of 3% of first 5 years and later 4% from the 6th to 10th year will be paid to new PIA separately as a part of AMC payment.	<p>This is our request for a modification to the financial bid table for the new shelters. Specifically, we propose adding a new line item for the comprehensive onsite replacement warranty rate, expressed as a percentage, to be quoted by each bidder.</p> <p>The new shelters feature several upgrades with sophisticated equipment and accessories, some of which are also installed in existing shelters. Due to these advancements and other potential factors, it may not be feasible for bidders to provide Annual Maintenance Contracts (AMC) for the new shelters at the currently fixed percentage rate.</p> <p>If the AMC percentage rate is not determined through this new line item, the upfront capital expenditure (capex) cost might be inflated, potentially leading to a financial disadvantage for GFGNL.</p> <p>To ensure fair pricing, we suggest imposing a maximum cap of 8 to 10% for this onsite replacement warranty rate.</p> <p>We believe this adjustment will provide a more accurate reflection of costs and ensure the financial interests of all parties involved.</p>	Duplicate Query, PI see preceding response above in Query-08

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
13	SECTION-3 <u>QUALIFICATION CRITERIA</u>	3.1 Eligibility Criteria	24	<p>Experience required One similar completed work Project</p> <p>*for One Package is Rs 16 Cr or 112 shelter</p> <p>*for both the package is Rs 26 Cr or 180 Shelters</p> <p># Definition of Similar Project: SITC or maintenance of IT/telecom Infra/Non-IT Infra such as Shelters /porta cabin to telecom/IP infrastructure provider/Tower Shelter, electrical work, Civil work related with Telecom/IT Site etc.</p>	<p>Regarding the definition of a Similar Project for your tender, we would like to clarify our eligibility based on our Operation & Maintenance (O&M) work experience with Telecom Shelter infrastructure.</p> <p>We have extensive experience covering more than 180 Telecom indoor shelters, focusing on the maintenance of installed equipment such as AC, SMPS, Battery Bank, DG, and FCU. Please note that supply work is not part of our experience in these projects. Apart from this, we are also having O&M work experience of more than 3000 Telecom outdoor sites.</p> <p>Could you please confirm if our O&M experience, as described above, meets the criteria for a "Similar Project" as defined in the tender documents? and can we eligible to apply for this tender based on our O&M work experience only ?</p>	PI see preceding response above in Query-01
14	Section-3	3.1 Eligibility criteria (Company Turnover) (Experience)	23 & 24	<p>The bidder should have average annual turnover as below from the business of telecom industry grade standardized shelter of at least 11 Cr for Single Package, 20 Cr for Two Package</p> <p>One similar completed work project not less than (one package) Rs 16 Cr or 112 shelters, (Both the package) Rs 26 Cr or 180 shelters.</p>	<p>Sir, we sincerely request you for the following -</p> <p>a) Eligibility criteria - Average annual turnover (Last 3 financial years) may please be revised to Rs 7 cr.</p> <p>b) Experience criteria - one similar completed work project - may please be revised to 70 no's telecom shelters</p> <p>c) As the work will be allotted on one package per bidder basis, there should be only one eligibility criteria for bidding in both the packages.</p> <p>We have satisfactorily executed orders of your esteemed organisation in past and we should be given a fair chance to be eligible and bid for this tender. Also we would like to bring to your kind notice that government of India has relaxed the prior experience and turnover criteria norms for MSME's. Circular attached with this mail for your</p>	PI see preceding response above in Query-01

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
					kind reference. Kindly give at least 50% relaxation for MSME in eligibility criteria.	
15	Fact sheet	Bid Security/Earnest Money Deposit (EMD) Amount Payable	13	Rs 1,07,65,000/- (Rs One Crore Seven Lakh Sixty-Five Thousand Only) per Package.	Kindly reduce the EMD amount to 1% of the project cost and allow participation in both the packages on one EMD	Duplicate Query. Pl see preceding response above in query-03 and factsheet revised section.
16	Section-7	Section 7.1 Payment criteria for new shelter	77	50% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order. 20% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order. 30% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order.	Kindly consider our sincere request for the following payment criteria - In order to meet the expected delivery timelines and efficient work, rotation of funds are extremely important for the PIA. Therefore, it is requested to revise the payment criteria as below - a) 80% payment to be released after completion of FAT b) 20% payment to be released after 3 months.	Pl see preceding response above .

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
17	SECTION-4 SCOPE OF WORK	4.3 Indicative diagram for proposed Solar System	38 & 39	Bidder has to consider up to 25% sites of overall scope to build solar panels including hybrid inverter based on intimation from GFGNL. Drawing:03 Solar System (outside) Physical Indicative Diagram	Considering the installation of solar panels on the shelter's roof, several factors lead us to advise against it at this time, primarily to save on capital expenditure for this project. (1) mounting the solar panels above the roof will result in a height exceeding 14 feet. This elevation will pose challenges for routine cleaning and maintenance. (2) the potential for shading from nearby buildings, trees, or other objects could significantly reduce the overall electricity generation efficiency of the solar panels. (3) the stability of the existing power supply grid may also negatively impact the consistency of solar power generation. (4) the limited roof space of approximately 10 square feet can only accommodate about four solar panels. This setup would ideally generate around 2.25 KW of power, which may not be sufficient. Based on these points, we request that you should not proceed with the installation of a solar power system for this project to avoid unnecessary capital expenditure.	Solar with hybrid inverter Scope is Removed

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
18	Section- 5	Technical specifications FCU	65	FCU specifications	<p>We request a reassessment of the feasibility of installing a Free Cooling Unit (FCU) in the existing and new telecom shelter, considering the following concerns:</p> <p>1) Structural Limitations: The existing shelter walls are only 80 mm thick, and there is no existing provision for FCU installation. Cutting the walls for FCU inlet and outlet ducts may pose significant challenges and could compromise the structural integrity of the shelter.</p> <p>2) Risk of Leakages: FCU installation in existing and new shelters could lead to water and air leakages, which may affect equipment safety and operational stability.</p> <p>3) Dust Ingress Risk: The FCU introduces fresh air from outside, which will carry dust and particulate matter. This could pose a risk to sensitive telecom equipment and other active components.</p> <p>4) Temperature Efficiency Constraint: FCU systems are only efficient when the outside temperature is 35°C or lower. During peak summer months, the system may not provide effective cooling, limiting its practical utility.</p> <p>5) Cost-benefit Viability: Given the above constraints and heavy cost of FCU, we request a cost-benefit analysis to determine if FCU installation remains a viable solution under current conditions.</p>	<p>Bidder has to understand the scope and objective of the project. Bidders with their expertise ensure to implement FCU components on critical collector nodes by ensuring implementation of dust free & water free mechanism(avoiding risk of dust, leakages, water, etc.) for better network quality and uptime. Before implementation of the site, bidder has to do the site survey and take prior approval from the tenderer authorized official.</p>

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
19	Section- 5	Technical specifications Solar panels	68	Solar Panels specifications	<p>We request your good office to kindly consider the following points in relation to the proposed installation of the solar system at existing / new telecom shelters:</p> <p>1) Structural Constraints- The existing telecom shelters have no pre-designed provision in their civil structure or RCC columns to accommodate solar installations. Therefore, new standalone RCC foundations will need to be constructed nearby. However, this additional civil work may pose a risk of damaging or weakening the existing structure due to close proximity and ground vibration during construction.</p> <p>2) Maintenance Requirements- Solar panels require regular cleaning, especially in remote or dusty regions, to ensure optimal performance. There is currently no defined mechanism for accessing the panels from outside for cleaning purposes. Moreover, clarity is needed on who will be responsible for the frequent periodic cleaning and maintenance of these systems.</p> <p>3) Space Constraints- Installing solar panels necessitates additional RCC columns and a separate steel support structure, which must be placed at a safe distance from the main shelter to prevent damage in shelter structure during high winds or storms. This will require more open and workable space. Accordingly, it may be necessary for GFGNL to apply for an additional space, other than shelter space, from the respective Gram Panchayats or relevant departments.</p> <p>4) Theft and Security Concerns- Even in urban environments, solar systems are</p>	Pl see preceding response above

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
					<p>susceptible to theft. Ensuring security in remote locations will be particularly challenging. Clear protocols must be defined for providing security and for assigning responsibility in case of theft or damage to the system.</p> <p>5) Location and Shading Issues- For maximum efficiency, solar panels need to be oriented towards the south. However, in several locations, natural and man-made obstructions such as trees, nearby buildings (including GP structures), and other installations may cast shadows on the panels, thereby significantly reducing their effectiveness.</p> <p><u>We kindly request that the above challenges be taken into serious consideration before introducing solar panel in telecom shelters . A comprehensive feasibility study and on-site evaluation and financial viability may be essential before proceeding in order to ensure structural safety, system efficiency, and operational and financial viability.</u></p> <p><u>However after the allocation of land , location and construction of shelters , GFGNL after evaluating the above points can take a call and float the tender for solar panels separately.</u></p>	

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
20	Technical Specification	Clause 9/Subclause 10	59	During testing of both the A/Cs, simulate all the alarms. We should get all the alarms on the controller in auto & manual modes.	Alarms are only available in controller when in auto mode. Manual mode option is to bypass all alarms to make the AC operational irrespective of any alarm. So, Alarms are not there in Manual mode. Need deviation in this as the purpose of manual mode is not served.	Alarms are for monitoring of devices and applicable for both auto and manual mode field operation.
21	Technical Specification	Clause 10/Subclause 1	59	Microprocessor type with ability of measuring ambient and shelter temperature and humidity and display through LED and alarm output	Humidity control/monitor feature is required for large AC in datacenter application only which sometime reduces the humidity due to excess cooling and hence it needs to be controlled along with cooling. In small rooms or small AC capacity (2+2 TR) the humidity is not that much affected and hence this feature is not provided. If required, then we can provide a humidity monitor as an additional accessory along with AC. Need deviation from humidity sensor if not important.	Humidity is important factor for active electronics. Either External or inbuilt humidity sensor with display and alarm is required.
22	Technical Specification	Section 5 - Technical Specifications - SMPS Battery	56	6. Alarm Extension -- The SMPS shall have advanced intelligent controller with ethernet interface supporting SNMP based communication for integration with GFGNL NMS to monitor specified parameters/alarms like overvoltage, battery on load, under voltage, temperature, door opening, smoke/fire detection, mains or battery discharge, etc. SMPS will have to send all these alarms towards NOC/NMS of GFGNL. OEM will have to share MIB file for necessary integration with NMS.	Necessary sensors for alarm extension to be provided within SMPS or it will be external to SMPS.	As mentioned the alarm should be through SMPS controller including all utilities like overvoltage, battery on load, under voltage, temperature, door opening, mains or battery discharge, etc. and other like smoke/fire detection. GFGNL will provide only single RJ45(Electrical) interface for alarm extension in network.

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
23	Technical Specification	Section 5 - Technical Specifications - SMPS Battery	56	4. Rectifier module / Capacity - - Adequate capacity to cater DC load of 60Amp for electronic equipments. Rectifier modules of min 80 Amp (N+1) / 4KW to be supplied. Bidder has to consider charging current requirement for battery back-up separately. Selected Bidder can provide minimum 2 nos. rectifier modules each having minimum 80 Amp capacity per each SMPS.	Whether load 60 Amp includes load current + battery charging current	Yes, however, It may vary per site. To avoid this, bidder has to do the field visit, measure the requirement and take prior approval before implementation from GFGNL official.
24	Technical Specification	Section 5 - Technical Specifications - SMPS Battery	56	7. Indications & Alarms -- The SMPS shall have LEDs for status indications and visual display to show alarms for output over voltage, overload or any module failure	SMPS should have option LED indication and/or LCD display	PI see preceding response above. This is mandatory and nonnegotiable for O&M.

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
25	Disclaimer	Disclaimer	6	Each Bidder should, therefore, conduct its own surveys and analysis and should check the accuracy, adequacy, correctness, reliability and completeness of the assumptions, assessments, statements and information contained in this RFP and obtain independent advice from appropriate sources before filling up the RFP. Any deviation in the specification or proposed solutions will be deemed as incapability of the respective Agency and shall not be considered for final evaluation process.	Site name,address & concern person contact details need to be shared by DST,GGNL where bidder need to carry out survey & analysis	Details are already available in Annexure-XVII. For additional details please send request on e-mail id with company authorized person e-mail id, contact numbers, ID details mentioned in clarification clause- 1.3(i.e., 1.3 Clarifications on the RFP)
26	Section 3: Qualification Criteria	Section 3: Qualification Criteria	28, 29	Firms taking exemption under MSME shall have to produce the certificate mentioning they are registered for manufacturing telecom grade shelter infrastructure like, Shelter along with AC, Power plant, battery, Servo Stabilizer, D.C. Fan/FCU, CCTV and Solar than only MSME exemption shall be accepted.	Are MSME registered firms also eligible for any exemption/discount for EMD/PBG in this tender?	Pl see preceding response above.

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
27	Section 4	Section 4	36	Pge no. 36: Apart from BOM, Apart from Bill of Material (BOM)/ Financial line items if anything is required in terms of component, Manpower, any hardware-software then the bidder needs to consider in financial bid cost and bidder needs to mention the detail of Items in the unpriced BOM/BOQ submitted.	Is it mean Bidder can submit "Priced BOM & Un priced BOM"? we request you to share detailed BOM required for new shelters & existing shelter upgradation. Technical configuration/specifications for Software to be shared by client	Clause is self-explanatory. No change in RFP
28		Section 7: Payment Criteria	76	Payment Terms: No advance will be made.	We request you to release "20% advance & balance 70% before delivery of material at client site against LC/RXIL/M1 Exchange/Invoice Mart/Any other billing dicount matter against submission of TPI report before dispatch & 10% against instalaltion & commisssioning" of Telcom shelters.	Pl see preceding response above.
29	Section 5	Section 5	56	Technical Specifications: SMPS Battery: 6: Alarm Extension -- The SMPS shall have advanced intelligent controller with ethernet interface supporting SNMP based communication for integration with GFGNL NMS to monitor specified parameters/alarms like overvoltage, battery on load, under voltage, temperature, door opening, smoke/fire detection, mains or battery discharge, etc. SMPS will have to send all these alarms towards NOC/NMS of GFGNL. OEM will have to share MIB file	Necessary sensors for alarm extension to be provided within SMPS or it will be external to SMPS. We understand that SMPS & 600Ah Li Battery will be inhouses in a single Rack. In that context,our query is whether necessary sensors for alarm extension to be accomodated in SMPS (i.e. within rack) or it will be external to SMPS (Comewhere outside of the rack).	Pl see preceding response above.

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
				for necessary integration with NMS.		
30	Section 5	Section 5	56	Technical Specifications: SMPS Battery: 7. Indications & Alarms -- The SMPS shall have LEDs for status indications and visual display to show alarms for output over voltage, overload or any module failure.	SMPS should have option LED indication and/or LCD display because LCD display to be preferred as it is more elaborative about indications.	PI see preceding response above.
31	Disclaimer	Disclaimer	6	Each Bidder should, therefore, conduct its own surveys and analysis and should check the accuracy, adequacy, correctness, reliability and completeness of the assumptions, assessments, statements and information contained in this RFP and obtain independent advice from appropriate sources before filling up the RFP. Any deviation in the specification or proposed solutions will be deemed as incapability of the respective Agency and shall not be considered for final evaluation process.	Site name, address & concern person contact details need to be shared by DST, GGNL where bidder need to carry out survey & analysis	PI see preceding response above.

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
32	Section 3: Qualification Criteria	Section 3: Qualification Criteria	28, 29	Firms taking exemption under MSME shall have to produce the certificate mentioning they are registered for manufacturing telecom grade shelter infrastructure like, Shelter along with AC, Power plant, battery, Servo Stabilizer, D.C. Fan/FCU, CCTV and Solar than only MSME exemption shall be accepted.	Are MSME registered firms also eligible for any exemption/discount for EMD/PBG in this tender?	PI see preceding response above
33	Section 4	Section 4	36	Pge no. 36: Apart from BOM, Apart from Bill of Material (BOM)/ Financial line items if anything is required in terms of component, Manpower, any hardware-software then the bidder needs to consider in financial bid cost and bidder needs to mention the detail of Items in the unpriced BOM/BOQ submitted.	Is it mean Bidder can submit "Priced BOM & Unpriced BOM"? we request you to share detailed BOM required for new shelters & existing shelter upgradation. Technical configuration/specifications for Software to be shared by client	PI see preceding response above
34	Section 7: Payment Criteria	Section 7: Payment Criteria	76	Payment Terms: No advance will be made.	We request you to release " 20% advance & balance 70% before delivery of material at client site against LC/RXIL/M1 Exchange/Invoice Mart/Any other billing dicount matter against submission of TPI report before dispatch & 10% against instalaltion & commissoning " of Telcom shelters.	PI see preceding response above

Sr.No	RFP Document Clause/ Section No.	Clause Title	Page No.	Content of the RFP Requiring Clarification	Clarification Sought	Response / Revised Clause
35	Section 5	Section 5	56	Technical Specifications: SMPS Battery: 6: Alarm Extension -- The SMPS shall have advanced intelligent controller with ethernet interface supporting SNMP based communication for integration with GFGNL NMS to monitor specified parameters/alarms like overvoltage, battery on load, under voltage, temperature, door opening, smoke/fire detection, mains or battery discharge, etc. SMPS will have to send all these alarms towards NOC/NMS of GFGNL. OEM will have to share MIB file for necessary integration with NMS.	Necessary sensors for alarm extension to be provided within SMPS or it will be external to SMPS. We understand that SMPS & 600Ah Li Battery will be inhouses in a single Rack. In that context,our query is whether necessary sensors for alarm extension to be accomodated in SMPS (i.e. within rack) or it will be external to SMPS (Comewhere outside of the rack).	PI see preceding response above
36	Section 5	Section 5	56	Technical Specifications: SMPS Battery: 7. Indications & Alarms -- The SMPS shall have LEDs for status indications and visual display to show alarms for output over voltage, overload or any module failure.	SMPS should have option LED indictaion and/or LCD display because LCD display to be preferred as it is more elaborative about indications.	PI see preceding response above

Annexure-B : Revised Criteria:

Sr No.	RFP Clause/Item Name	Original Clause	Revised Clause/Clarifications
1.	Clause_9.5 Bid Security/ Earnest Money Deposit (EMD)	i. Bidders shall submit, along with their Bids, EMD of Rs 1,07,65,000,-(Rs. One Crore Seven Lakh Sixty-Five Thousands Only) per package in the form of an unconditional Bank Guarantee or Insurance surety bond by Bank Guarantee which should be valid for 225 days from the last date of bid submission) prescribed by the TENDERER of any Nationalized Bank including the public sector bank or Private Sector Banks or Commercial Banks or Co-Operative Banks and Rural Banks (operating in India having branch at Ahmedabad/ Gandhinagar) as per the GR No. FD/MSM/e-file/4/2023/4020/D.M.O. dated 11-03-2024 issued by Finance Department or further instruction issued by Finance department time to time; in the name of "Gujarat Fibre Grid Network Limited."/DBN/CCA-Gujarat payable at Gandhinagar (in the specified format and must be submitted along with the covering letter	i. Bidders shall submit, along with their Bids, EMD of Rs 1,07,65,000,-(Rs. One Crore Seven Lakh Sixty-Five Thousands Only) Rs 60,000,00 /- (Rupees Sixty Lakhs Only) per package in the form of an unconditional Bank Guarantee or Insurance surety bond by Bank Guarantee which should be valid for 225 days from the last date of bid submission) prescribed by the TENDERER of any Nationalized Bank including the public sector bank or Private Sector Banks or Commercial Banks or Co-Operative Banks and Rural Banks (operating in India having branch at Ahmedabad/ Gandhinagar) as per the GR No. FD/MSM/e-file/4/2023/4020/D.M.O. dated 11-03-2024 issued by Finance Department or further instruction issued by Finance department time to time; in the name of "Gujarat Fibre Grid Network Limited."/DBN/CCA-Gujarat payable at Gandhinagar (in the specified format and must be submitted along with the covering letter. This is as per Manual of procurement works June-2022 of Government of India(Gol).
2.	Section:4 (Scope of Work)	Scope related to Solar System with Hybrid Inverter	Scope Removed.
3.	4.9(k)	k) Selected Bidder will have to do the shifting of shelter Infrastructure site (including all the items supplied & installed under the SoW of this RFP) from one location to other within (50 Km of radius range) if need arises in future for same & instructed by GFGNL. Shifting scope may vary up to 10% of total scope awarded without any additional cost to GFGNL. Beyond the 10% of the shifting scope, per site beyond the limit define above, GFGNL will pay Rs 50,000/- per site to selected bidder.	k) Selected Bidder will have to do the shifting of shelter Infrastructure site (including all the items supplied & installed under the SoW of this RFP) from one location to other within (50 Km of radius range) if need arises in future for same & instructed by GFGNL. Shifting scope may not vary beyond 10% of total scope awarded. GFGNL will pay Rs 1,00,000/- per site shifting and re-installation including civil, non-IT ,and all the supplied components under the scope of this RFP to the selected PIA. PIA has to complete the shifting within 30 calendar days of time including commissioning and acceptance test.

Annexure-C : Pre-Qualification Criteria:

Sr. No	Description	Eligibility Criteria	Supporting Documents to be furnished												
1.	Legal Entity	<p>1.1 The bidder should be registered under the Companies Act 1956/2013 in India or a Limited Liability Partnership Firm under Limited Liability Partnership Firm Act 2008/1932 at the time of the bidding submission date.</p> <p>1.2 The bidder should have a registered number of, GST, Income Tax / Pan number.</p> <p>1.3 The bidder should be in operation in India for a period of at least 5 years as on publication of this tender.</p>	<p>a) Copy of Certificate of Incorporation signed by Authorized Signatory of the Bidder or A copy of the partnership deed/ instrument of partnership or a Copy of LLP agreement or Registration certificate.</p> <p>b) Copy of PAN card.</p> <p>c) Copy of GST registration.</p>												
2.	Company TurnOver	<p>The bidder should have average annual turnover of at least as per below matrix from the business of Telecom industry grade standardized Shelter business/deployment in the last three (3) audited financial years (i.e., FY 2021-22, FY 2022-23 and FY 2023-24) or FY 2022-23, FY 2023-24 and FY 2024-25(non-audited))</p> <table><tr><th>Sr No.</th><th>Bid for Single Package</th><th>Bid for two Packages</th></tr><tr><td>A</td><td>11 Cr</td><td>20 Cr</td></tr></table> <table><tr><th>Sr No.</th><th>Bid for Single Package</th><th>Bid for two Packages</th></tr><tr><td>A</td><td>9 Cr</td><td>17 Cr</td></tr></table> <p>Note: Turnover considered would be a consolidated turnover of the company i.e. A parent Company can use the turnover of its subsidiaries (more than 50% holding) but a child company cannot use parent company's turnover. However, both the company should have same domain experience and both incorporated,</p>	Sr No.	Bid for Single Package	Bid for two Packages	A	11 Cr	20 Cr	Sr No.	Bid for Single Package	Bid for two Packages	A	9 Cr	17 Cr	<p>For Annual Turnover:</p> <p>a) Copy of audited Balance Sheet, audited Profit & Loss statements for each of the last 3 financial years</p> <p>b) Copy of Certificate from the statutory auditor / Chartered Accountant (CA) clearly specifying the annual turnover for each of the last 3 audited financial years, i.e. (FY 2021-22, FY 2022-23, and FY 2023-24) or last three(3) financial years (i.e., FY 2022-23, FY 2023-24 and provisional certificate of FY 2024-25(non-audited))</p> <p>c) For MSE under the Official Memorandum(20th September 2016 & 27th January 2022), 50% relaxation under asked turnover is eligible .</p> <ul style="list-style-type: none">MSE (Micro & Small Enterprise) bidders are exempted from 50% of company turnover provided they submit current and valid Udyam Registration Certificate (URC)/ NSIC (National Small Industries Corporation) /CSPO issued from the Ministry of MSME registered under
Sr No.	Bid for Single Package	Bid for two Packages													
A	11 Cr	20 Cr													
Sr No.	Bid for Single Package	Bid for two Packages													
A	9 Cr	17 Cr													

Sr. No	Description	Eligibility Criteria	Supporting Documents to be furnished												
		registered, and established in a country not sharing a land border with India	Udyam Registration to avail the benefits under the policy.												
3.	Positive Network	The bidder should have positive net worth in last three financial year (i.e., FY 2021-22, FY 2022-23 and FY 2023-24)	For Positive net worth: a) Certificate from the Statutory Auditor on net worth (i.e. FY 2021-22, FY 2022-23, and FY 2023-24)												
4.	Experience	<p>Bidder should have relevant experience of executing below mentioned project for State / Central Government / PSU /SPV/BFSI in India over last 8 years as on bid submission date:</p> <table><tr><th>Project (with maximum two (2) organizations in last 8 years)</th><th>One Package</th><th>Both the Package</th></tr><tr><td>One similar completed work Project not less than</td><td>Rs 16 Cr or 112 Shelters</td><td>Rs 26 Cr or 180 Shelters</td></tr><tr><td>Or Two similar completed work Project not less than</td><td>Rs 9.8 Cr each Or 70 Shelters</td><td>Rs 16 Cr each Or 112 Shelters</td></tr><tr><td>Or Three similar completed work Project not less than</td><td>Rs 7.8 Cr Or 56 shelters</td><td>Rs 12.5 Cr Or 90 shelters</td></tr></table>	Project (with maximum two (2) organizations in last 8 years)	One Package	Both the Package	One similar completed work Project not less than	Rs 16 Cr or 112 Shelters	Rs 26 Cr or 180 Shelters	Or Two similar completed work Project not less than	Rs 9.8 Cr each Or 70 Shelters	Rs 16 Cr each Or 112 Shelters	Or Three similar completed work Project not less than	Rs 7.8 Cr Or 56 shelters	Rs 12.5 Cr Or 90 shelters	<p>For completed projects WO copy with any of one document as legitimate evidence for claimed experience from client.</p> <p>i) Successful Go-live Certificate, Or ii) Successful Acceptance Test Report, Or iii) Successful Work completion Certificate Any of this with satisfactory performance & functionalities implemented may be mentioned separately as a performance certificate from the client.</p> <p>For ongoing projects WO copy contract copy with any one of document as legitimate evidence for claimed experience from client clearly stating the deliverables and equipment , i) Successful Go-live Certificate, Or ii) Successful Acceptance Test Report, Or iii) Successful Work Experience Certificate</p> <p>Performance certificate from end client mentioning satisfactory performance & functionalities implemented by the bidder with</p>
Project (with maximum two (2) organizations in last 8 years)	One Package	Both the Package													
One similar completed work Project not less than	Rs 16 Cr or 112 Shelters	Rs 26 Cr or 180 Shelters													
Or Two similar completed work Project not less than	Rs 9.8 Cr each Or 70 Shelters	Rs 16 Cr each Or 112 Shelters													
Or Three similar completed work Project not less than	Rs 7.8 Cr Or 56 shelters	Rs 12.5 Cr Or 90 shelters													

Sr. No	Description	Eligibility Criteria			Supporting Documents to be furnished												
		<table><tr><th>Project (with maximum two (2) organizations in last 8 years)</th><th>One Package</th><th>Both the Package</th></tr><tr><td>One similar completed work Project not less than</td><td>Rs 15 Cr or 112 Shelters</td><td>Rs 24 Cr or 180 Shelters</td></tr><tr><td>Or Two similar completed work Project not less than</td><td>Rs 9.5 Cr each Or 70 Shelters</td><td>Rs 15 Cr each Or 112 Shelters</td></tr><tr><td>Or Three similar completed work Project not less than</td><td>Rs 7.5 Cr Or 56 shelters</td><td>Rs 12 Cr Or 90 shelters</td></tr></table>	Project (with maximum two (2) organizations in last 8 years)	One Package	Both the Package	One similar completed work Project not less than	Rs 15 Cr or 112 Shelters	Rs 24 Cr or 180 Shelters	Or Two similar completed work Project not less than	Rs 9.5 Cr each Or 70 Shelters	Rs 15 Cr each Or 112 Shelters	Or Three similar completed work Project not less than	Rs 7.5 Cr Or 56 shelters	Rs 12 Cr Or 90 shelters			<p>minimum 50% of SITC work has been accomplished from the client.</p> <ul style="list-style-type: none">• The client’s name with authorized contact person name, reachable postal address, official email id and telephone numbers are must for official verification.• Any misleading/fake information shall result into disqualification of bid with forfeiture of EMD and will be debarred for further participation in any of the GFGNL bid. <p>For MSE under the Official Memorandum(20th September 2016 & 27th January 2022), 50% relaxation under asked Experience is eligible .</p> <ul style="list-style-type: none">• MSE (Micro & Small Enterprise) bidders are exempted from 50% of experience asked provided they submit current and valid Udyam Registration Certificate (URC)/ NSIC (National Small Industries Corporation) / CSPO issued from the Ministry of MSME registered under Udyam Registration to avail the benefits under the policy.
Project (with maximum two (2) organizations in last 8 years)	One Package	Both the Package															
One similar completed work Project not less than	Rs 15 Cr or 112 Shelters	Rs 24 Cr or 180 Shelters															
Or Two similar completed work Project not less than	Rs 9.5 Cr each Or 70 Shelters	Rs 15 Cr each Or 112 Shelters															
Or Three similar completed work Project not less than	Rs 7.5 Cr Or 56 shelters	Rs 12 Cr Or 90 shelters															
		<p>Definition of Similar Project: SITC or maintenance of IT/telecom Infra/Non-IT Infra such as Shelters /porta cabin to telecom/IP infrastructure provider/Tower Shelter, electrical work, Civil work related with Telecom/IT Site etc.</p> <p>For completed projects</p> <ul style="list-style-type: none">• If WO date is older than Eight (8) years from bid released date(excluding bid released date), then work completion certificate must not be older than 7 years from bid released date.• If WO date & Work completion date falls within Eight (8) years from bid released date(excluding bid released date), it is ok. <p>For ongoing projects</p>															

Sr. No	Description	Eligibility Criteria	Supporting Documents to be furnished
		<ul style="list-style-type: none"> WO date must be earlier than one (1) year from bid released date(excluding bid released date). <p>Note 1: The technical experience (on active elements only) for work executed in foreign countries for TSPs or Government shall also be considered.</p>	
5.	MAF	<p>The Bidder should submit valid letter from each of the OEM (maximum two(2) OEM for each component) - confirming the following: OEM shall ensure that all equipment/components/sub-components being supplied by them shall be supported for entire contract period. If the same is de-supported by the OEM for any reason whatsoever, The Bidder shall replace it with an equivalent or better substitute that is acceptable to Tenderer without any additional cost to the Tenderer and without impacting the performance of the solution in any manner whatsoever. In case replacement with a product from an OEM other than the OEMs proposed by the bidder prior approval from GFGNL will be required.</p> <p>Note: Maximum two MAF are allowed. clearly mentioning the Primary MAF and Secondary MAF. The bidder has no choice to shift the secondary MAF to Primary MAF in any conditions.</p>	<p>Documentary evidence such as Authorization letters, MAF (Annexure VII) from all OEM/Vendors whose products are being quoted by the Bidder need to be attached in the bid.</p> <p>Copy of valid Mandatory Testing and Certification of Telecommunication Equipment(MTCTE)/ Type Approval Certificate or copy of Application for fresh MTCTE/TAC/TSEC as applicable from each OEM whose products are being quoted by the Bidder.</p> <p>Quoted product like SMPS and Battery should have TEC/TSEC or bidders may also submit copy of previous TSEC of any SMPS, any Battery to meet the eligibility Or OEM self undertaking to certifying that supplied items are TEC /TSEC complied for submitting the bid only. However, the PIA/ OEM shall submit the valid TSEC as per the Technical Specifications in this RFP, before supply/installation of the product.</p> <p>MAF is required for each of the components, i.e., shelter, air conditioner, SMPS, rectifier, Battery bank, CCTV, solar, NVR, servo stabilizer, FCU and all other equipments quoted in this RFP.</p>
6.	Make In India Policy (MII) and Land Border	The bidder(sole or lead & consortium members) shall not be allowed for purchase of active and passive equipment's, and services of security, validation & functional tests devices, ground	Self-certification from bidder and OEMs on Non-Judicial stamp of Rs. 300/- in the prescribed format (Annexure – XI), separately.

Sr. No	Description	Eligibility Criteria	Supporting Documents to be furnished
		<p>machinery for execution like excavators, manpower, sub-contract to contractors and other resources of proposed solution from a country which shares a land border with India unless such is registered with Competent Authority as per OM No. 6/18/2019-PPD dated 23rd July 2020 issued by Department of Expenditure, Gol and should be in compliance with make in India policy (guidelines of Gol issued vide No. P-45021/2/2017-PP(B.E.-II) dated 16th September, 2020, No. P-45021/102/2019-BE-II-(part(I) (E-50310) dated 04.03.2021 and Department of Telecommunications Gazette notification dated 29th August 2018, 21st October 2024 along with instructions as amended from time to time by Govt. of India) for promoting domestic manufactures.</p>	

Sr. No	Description	Eligibility Criteria	Supporting Documents to be furnished
7.	Mandatory Undertaking	<p>The Sole, and any of the consortium members & OEM should:</p> <p>7.1 Not have been blacklisted/debarred/terminated by Ministry of Communication or GFGNL or debaring order issued by Department of Expenditure (DOE), Ministry of Finance (MOF) covering all central Ministries/ Departments as per provision of OM No.F.1/20/2018-PPD by Department of Expenditure (DoE)/ MoF dated on 2nd Nov 2021/ Central Government / Any State Government / SPV/ Urban Local Body (ULB) /SmartCity / Supreme Court of India / Any government / PSU in India as on the date of bid submission."</p> <p>7.2 Not be insolvent, in receivership, bankrupt or being wound up, not have its affairs administered by a court or a judicial officer, not have its business activities suspended and must not be the subject of legal proceedings for any of the foregoing reasons.</p> <p>7.3 The Bidder should have at least one office in Gujarat and preferably support centers /logistics for the entire state. If the Bidder is not having any office in Gujarat, then bidder should submit a letter of undertaking to open the office in Gujarat within 45 days from the date of issue of work order if he is awarded the work.</p> <p>7.4 Not have their directors and officers convicted of any criminal offence related to their professional conduct or the making of false statements or misrepresentations as to their qualifications to enter into a procurement contract within a period of three years preceding the commencement of the procurement process, or not have been otherwise disqualified.</p> <p>7.5 There must not be any criminal case booked by any Government authority against the bidder in any court in last 5 years as on bid submission date</p>	An undertaking signed by CEO/ Country Head/ Authorized Signatory of the company to be provided on Non – judicial stamp paper of INR 100/- or such equivalent amount and document duly attested by notary public (in format (Annexure – IV) separately.
8.	Certification	<p>The bidder should have atleast one certificates from following valid as on bid submission date,</p> <ul style="list-style-type: none"> i) ISO 9001:2015, ii) RoHS, iii) IS 13252 certification, 	Copies of valid certificates in the name of the bidding entity

Sr. No	Description	Eligibility Criteria	Supporting Documents to be furnished
		iv) ISO 27001 for Information Security Management Systems.	
9.	Bharatnet Project	If a bidder has been declared as non-performer in any Digital Bharat Nidhi (DBN) project(s) such as BharatNet Project and 4G saturation project, on the bid submission date, such bidder shall stand not eligible to submit the bid for this tender.	A Self-declaration with company stamp by the bidder for not being declared as non-performer in any Digital Bharat Nidhi (DBN) project(s), as per the clause.

Annexure-D : Technical-Qualification Criteria:

S/N	Criteria	Evaluation Criteria Details (for each Package)	Documentary Proof	Max. Marks
1	Experience Capability	<p>Bidder Should have executed with Supply, Installation, Testing, Commissioning (SITC) or O&M experience with atleast following shelters counts in last 8 Years from the date of bid publish with Civil, Electrical, Air conditioners, Power plant and battery banks</p> <p>A- ≥ 200 Numbers</p> <p>B- ≥ 150 to < 200 Numbers</p> <p>C- ≥ 110 to < 150 Numbers</p> <p>Note: For MSE 50% relaxation</p>	<ul style="list-style-type: none"> Bidder has to submit the end client PO/WO with satisfactory completion certificate with deliverable (by mentioning minimum porta cabin shelter, civil activities, electrical utilities, power plant -Battery banks, air conditioners,etc.) and counts of shelter. 	10

S/N	Criteria	Evaluation Criteria Details (for each Package)	Documentary Proof	Max. Marks
2	Clientele Base	<p>Total Number Of Customer base served: Total number of customer base experience on Telecom grade shelter (including Civil, Electrical, Air conditioners, Power plant and battery banks works) with Supply, Installation, Testing, Commissioning (SITC) in last Eight (8) years from the date of bid publish _____ date.</p> <p>Note:</p> <p>A. _____ Top 2 rank</p> <p>B. _____ Top 3 to 5 rank</p> <p>C. _____ For remaining rank</p>	<p>• Bidder has to submit the end client PO/WO with satisfactory completion certificate with deliverable(by mentioning minimum portacabin Shelter, civil activities, electrical utilities, power plant Battery banks, air conditioners, etc.) and counts of shelter.</p>	10
3	Offered product portfolio	<p>Quality products / components (Telecom grade Shelter, Battery Bank, Servo Stabilizer CCTV, Fire Suppression System, SMPS, Rectifier as part of this RFP scope)</p> <ul style="list-style-type: none"> Supplied quantities in past 5 years from the bid submission date (15 score) <p>Note: The score will be defined based on percentile and this rollout commitment shall be the prime essence of the contract. This commitment may serve as the primary consideration.</p> <ul style="list-style-type: none"> Repair & return commitment for active components (10 score) <ul style="list-style-type: none"> A. <= 48 Hours B. >48 Hours to <= 72 Hours C. >72 Hours to <= 96 Hours 	<ul style="list-style-type: none"> The comparative ranking among all the bid participants will be considered for each of the parameters. Delivery Challan/PO/WO Copy Faster repair & return commitment basis on company letter head 	25

S/N	Criteria	Evaluation Criteria Details (for each Package)	Documentary Proof	Max. Marks
4	Network Uptime Commitment	<p>Commitment on Minimum Up-time for all shelter components including power protection and shelter during entire contract duration:</p> <p>A >= 99.5%</p> <p>B >=99.25 % to <99.5%</p> <p>C >=99% to <99.25 %</p>	<ul style="list-style-type: none"> Bidder has to submit the Self declaration with company stamp on their company letter with authorized signatory Legitimate undertaking as part of revision in the contract for penalty calculation Anyone proof of previous project on achievement of Uptime and MTTR for quarterly basis as a past performance 	15 20
5	Early Roll-out commitment	<p>Bidder can showcase their expertise and give revise milestone for early rollout of the project, by defining following,</p> <ul style="list-style-type: none"> Confirmation on above the define lot size, and Delivery timelines <p>Note: The score will be defined based on percentile and this rollout commitment shall be the prime essence of the contract. This commitment may serve as the primary consideration.</p>	<ul style="list-style-type: none"> For record purpose, commitment calculation will be based on the following formula Commitment = > (Size of the lot/ Delivery Timelines). * Bidder has to submit the Self declaration with company stamp on their company letter with authorized signatory 	25

S/N	Criteria	Evaluation Criteria Details (for each Package)	Documentary Proof	Max. Marks
6	Additional Offering	<p>Additional Offering over and above the ask of RFP without additional charges to GFGNL. For example below but not limited to,</p> <p>i) Shelter safety and security. ii) Automation and Remote Monitoring with best emerging technologies. iii) Assurance of high quality specifications. iv) Branding and Monetization commitment. v) Any other significant creative offering</p> <p>Note: On fulfillment of above offering, A. Any 4 offering out of 5 B. Any 3 offering out of 5 C. Any 2 offering out of 5</p> <p>Marking will be given based on percentile of highest commitment from the bidder. This will be part of the contract and deliverables. Same shall be diligently applied in WO/Agreement</p>	<ul style="list-style-type: none"> Bidder has to submit the Self declaration with company stamp on their company letter with authorized signatory 	15 20
Total Marks				100

Financial Bid Format For Each Package

#	Description	UoM	Pkg-A	Unit Price	Total Price(INR)	Taxes as applicable (%)	Total With Tax(INR)
			(count)				
			(A)	(B)	C= A*B	(D)=Tax %	(E)=C*D
17	Supply, Installation, testing & commissioning FM200-Fire Suppression System /Clean Agent(5Kg) with 5 years +5 years extended onsite replacement warranty	Nos.	354 75				
19	Supply, Installation, testing & commissioning Free Colling Unit(FCU) with 5 years +5 years extended onsite replacement warranty(*Bidder has to quote the capex amount,as warranty/AMC fixed price will be paid separately as per clause_9.17)	Nos.	354 75				
20	Supply, Installation, testing & commissioning of CCTV(Indoor) with 5 years +5 years extended onsite replacement warranty(*Bidder has to quote the capex amount,as warranty/AMC fixed price will be paid separately as per clause_9.17)	Nos.	354 75				
21	Supply, Installation, testing & commissioning of 4 Channel NVR with 5 years +5 years extended onsite replacement warranty(*Bidder has to quote the capex amount,as warranty/AMC fixed price will be paid separately as per clause_9.17)	Nos.	88 19				
27	Supply, Installation, testing & commissioning of Solar System at roof top on shelter with pole mount and other accessories and it's controller with all necessary solar panels, civil and mechanical works, to make the successfully commission the site with 10 years of extended onsite replacement warranty. (*Bidder has to quote the capex amount,as warranty/AMC fixed price	Nos.	88				

#	Description	UoM	Pkg-A	Unit Price	Total Price(INR)	Taxes as applicable (%)	Total With Tax(INR)
			(count)				
			(A)	(B)	C= A*B	(D)=Tax %	(E)=C*D
	will be paid separately as per clause_9.17)						
28	Supply, Installation, testing & commissioning Structured electrical wiring for Solar System with accessories such as casing capping/ Conduit, mounting clamp, MCB etc. to make the successfully commission the site with 10 years of extended onsite replacement warranty. (*Bidder has to quote the capex amount,as warranty/AMC fixed price will be paid separately as per clause_9.17)	Nos.	88				

Table-0A(For Package-A)

#	Description	UoM	Pkg-B	Unit Price	Total Price(INR)	Taxes as applicable (%)	Total With Tax(INR)
			(count)				
			(A)	(B)	C= A*B	(D)=Tax %	(E)=C*D
17	Supply, Installation, testing & commissioning FM200-Fire Suppression System /Clean Agent(5Kg) with 5 years +5 years extended onsite replacement warranty	Nos.	312 75				
19	Supply, Installation, testing & commissioning Free Colling Unit(FCU) with 5 years +5 years extended onsite replacement warranty(*Bidder has to quote the capex amount,as warranty/AMC fixed price will be paid separately as per clause_9.17)	Nos.	312 75				
20	Supply, Installation, testing & commissioning of CCTV(Indoor) with 5 years +5 years extended onsite replacement warranty(*Bidder has to quote the capex amount,as warranty/AMC fixed price will be paid separately as per clause_9.17)	Nos.	312 75				

#	Description	UoM	Pkg-B	Unit Price	Total Price(INR)	Taxes as applicable (%)	Total With Tax(INR)
			(count)				
			(A)	(B)	C= A*B	(D)=Tax %	(E)=C*D
21	Supply, Installation, testing & commissioning of 4 Channel NVR with 5 years +5 years extended onsite replacement warranty>(*Bidder has to quote the capex amount,as warranty/AMC fixed price will be paid separately as per clause_9.17)	Nos.	78 19				
27	Supply, Installation, testing & commissioning of Solar System at roof top on shelter with pole mount and other accessories and it's controller with all necessary solar panel's, civil and mechanical works, to make the successfully commission the site with 10 years of extended onsite replacement warranty. (*Bidder has to quote the capex amount,as warranty/AMC fixed price will be paid separately as per clause_9.17)	Nos.	78				
28	Supply, Installation, testing & commissioning Structured electrical wiring for Solar System with accessories such as casing capping/ Conduit, mounting clamp, MCB etc. to make the successfully commission the site with 10 years of extended onsite replacement warranty. (*Bidder has to quote the capex amount,as warranty/AMC fixed price will be paid separately as per clause_9.17)	Nos.	78				

7.1 Payment criteria for New Shelter

#	Milestone	Deliverables	For New Shelter	Payment
1	SITC of supplied equipment as per scope of work of this RFP and completion of conditional acceptance	i) Delivery Challan ii) Invoice Copy iii) Installation and commissioning Report with photos and LLD along with conditional acceptance report from GFGNL or its authorized agency	T5 = T4+90 calendar Days	50% 65% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order
2	Cooling Period of 3 Months for Stability	i) FAT: Clearance of all punch points of infrastructure site with all equipments and submission of final acceptance test report from GFGNL or its authorized agency. ii) Warranty assurance certificate (yearly and commitment for 10 years) warranty/AMC payment issued by respective OEMs for each hardware Submission of Site valid Insurance copy warranty assurance certificate subjected to yearly warranty/AMC certificate	T6=T5 + 90 calendar Days	20% 15% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order
3	After 1 year of defect liability period after commissioning	99% network uptime for each month of each component	T7=T6+365 calendar Days	30% 20% Capex value of Total work value for 1 porta cabin with infrastructure as mentioned in the execution order

#	Milestone	Deliverables	For New Shelter	Payment
		<p>Meet the expectation of section 8 subclause iv for SLA for the Hardware/Service component.</p> <p>Submission of Site valid Insurance copy</p> <p>warranty assurance certificate subjected to yearly warranty/AMC certificate</p>		

Note:

The line items/ clause not attributable to the bidder and not in control of the selected bidder (like if BharatNet Phase-III PIA network elements not integrated at Shelter) will be excluded for penalty.

7.2 Payment criteria for Existing Shelter Upgradation

Sr No	Milestone	Deliverables	For Existing Shelter Upgradation	Payment
1	SITC of supplied equipment as per scope of work of this RFP for existing BharatNet Phase-II (For the cases of existing Shelter upgradation) and completion conditional acceptance	<p>i) Delivery Challan</p> <p>ii) Invoice Copy</p> <p>iii) Installation and commissioning Report with photos and LLD alongwith conditional acceptance report from GFGNL or it's authorized agency</p>	T4 = T3+30 calendar Days	50% 65% of total value of material installed at various sites as derived from the certified installed quantity and unit price discovered in priced BOQ in given existing porta cabin(shelter).

Sr No	Milestone	Deliverables	For Existing Shelter Upgradation	Payment
2	Cooling Period of 3 Months for Stability	<p>i) FAT: Clearance of all punch points of infrastructure site with all equipments and submission of final acceptance test report from GFGNL or it's authorized agency .</p> <p>ii) Warranty assurance & Insurance certificate (yearly and commitment for 10 years) warranty/AMC payment issued by respective OEMs for each hardware</p>	T5=T4 + 90 calendar Days	20% 15% of total value of material installed at various sites as derived from the certified installed quantity and unit price discovered in priced BOQ in given existing porta cabin(shelter).
3	After 1 year of defect liability period after commissioning	<p>99% network uptime for each month of each component</p> <p>Warranty and extended warranty Certificates of OEM</p> <p>Meet the expectation of section 8 subclause iv for SLA for the Hardware/Service component.</p> <p>Submission of Site valid Insurance copy</p> <p>warranty assurance certificate subjected to yearly warranty/AMC certificate</p>	T6=T5+365 calendar Days	30% 20% of total value of material installed at various sites as derived from the certified installed quantity and unit price discovered in priced BOQ in given existing porta cabin(shelter).

Annexure XVII: Existing Inventories for AMC is required.

Refer Master RFP Revised Annexure XVII for Existing Shelter AMC Details which includes active and passive infrastructures built under shelter.

=====End Of Document=====